

R32 for Air Conditioning

- a low GWP, low flammable solution

R32 is proposed to be used in some air conditioning equipment which currently uses R410A so this bulletin is an introduction to this refrigerant. It is mildly flammable and has similar performance and operating conditions to R410A. It has a lower global warming potential (GWP) than the commonly used HFCs.

Characteristics

R32 is difluoromethane (methylene fluoride) and it is an HFC type refrigerant. R32 has been used for many years as a component of both R407C and R410A. It is flammable on its own, but not when mixed with the other components of these blends.

Table 1 below summarises its main characteristics in comparison with HFCs R410A and R407C, and hydrocarbon R290 (propane). The information is from EN378-1:2008+A2:2012, Refrigerating systems and heat pumps – Safety and environmental requirements, Part 1 – Basic requirements, definitions, classification and selection criteria. See Table 2 for an explanation of A1, A2 and A3.

Flammability

Refrigerants are classified according to their flammability and toxicity. "A" classification indicates low toxicity ("B" is high toxicity). The numbers 1, 2 or 3 following the A or B indicate the degree of flammability. The safety groups A1, A2 and A3 are explained in the table below:

Working safely with R32

You should take the same care when handling R32 as you do for the hydrocarbon refrigerants. The following points summarise the safe handling guidance:

- Work in a well-ventilated area;
- Eliminate sources of ignition within 3 m of the system and associated service equipment;
- Use a suitable detector to warn of a build-up of flammable refrigerant in the air;
- Have a fire extinguisher available;
- Ensure your recovery machine is safe to use with flammable refrigerant;

Cont./

Table 1 - Refrigerant characteristics

	Boiling point	Safety group	Lower flammability level kg/m ³	Practical limit kg/m ³	Ignition temp	GWP
R32	-51°C	A2	0.307	0.061	648°C	550
R410A	-52°C	A1	-	0.44	-	1980
R407C	-44°C to -37°C	A1	-	0.31	704°C	1650
R290	-42°C	A3	0.038	0.008	470°C	3

Table 2 - Refrigerant flammability classification

Safety classification	Lower Flammability level, % in air by volume	Heat of combustion, J/kg	Flame propagation
A1		No flame propagation when tested at 60°C and 101.3 kPa	
A2, lower flammability	> 3.5	< 19,000	Exhibit flame propagation when tested at 60°C and 101.3 kPa
A3, higher flammability	≤ 3.5	≥ 19,000	Exhibit flame propagation when tested at 60°C and 101.3 kPa

R32 for air conditioning cont

page 2

- Use leak detection spray or a safe, sensitive electronic leak detector;
- If you need to un-braze connections ensure you have recovered the system onto a vacuum and filled with a charge of dry nitrogen to a slight positive pressure before un-brazing;
- When evacuating the system ensure the vacuum pump is in a well-ventilated area (or outside) and control it by a switch outside the 3m area.

You should refer to the detailed information provided by the suppliers or training providers.

Charge size limitations (as specified in the current EN378-1:2008)

The amount of flammable refrigerant which can be used in systems is restricted and depends on a number of factors:

- Location of equipment, e.g. below or above ground level;
- Occupancy of area being cooled, e.g. unrestricted access by the public or authorised access only;
- Type of system, e.g. direct expansion or secondary / refrigeration or air conditioning.

The limits are different for comfort cooling / heating and non comfort cooling / heating applications.

R32 is proposed for use in split air conditioning systems, so the most common charge size restriction is that applying to comfort cooling / heating applications. The maximum charge is based on the LFL of the refrigerant, the floor area and the height of the indoor unit:

$$M = 2.5 \times \text{LFL}^{1.25} \times h \times \sqrt{A}$$

M = max charge, kg

LFL = lower flammability limit, kg/m³

h = height of unit, m, (0.6 for floor mounted, 1.0 for window, 1.8 for wall, 2.2 for ceiling)

A = floor area, m²

Example of charge size limitation calculation

A split AC system with a ceiling mounted indoor unit in a room 9 m long by 5.5 m wide using R32:

$$M = 2.5 \times 0.307^{1.25} \times 2.2 \times \sqrt{(9 \times 5.5)} = 8.84 \text{ kg}$$

In this application the maximum charge size for R290 (propane) would be 0.65 kg because of its greater LFL. For this reason R32 can be more widely applied.

For non comfort cooling and heating applications the maximum charge is calculated using the practical limit, and there are also absolute maximum charge sizes – these are detailed in EN378.

About ACHPI

The Air Conditioning and Heat Pump Institute (ACHPI) publishes a library of up to date and practical information for improving air conditioning and heat pump efficiency.

- keep up to date with news
- broaden knowledge of current technology
- fill gaps in theory and fundamentals
- signpost new developments track changes to legislation

Find out how you could be a member at
www.ior.org.uk/achpi